

No. G-4(vi)/DJB/Dir.(A&P)/ Monsoon-2019/ **Unst. 50/CM-06**
DELHI JAL BOARD, GOVT. OF NCT OF DELHI
OFFICE OF THE DIRECTOR (ADMN. & PERSONNEL)
VARUNALAYA PHASE-II, KAROL BAGH, NEW DELHI – 110 005

Dated 21.08.2019

To

Shri Mahendra Gupta
Dy. Secretary, (Question Branch),
Delhi Vidhan Sabha Secretariat,
Old Secretariat, Delhi – 110054.

**Subject:- Vidhan Sabha Un-starred Question No. 50 due for
22.08.2019 asked by Shri Rajesh Gupta, MLA.**

Sir,

Please refer to letter No. F-11(B-1)VI/2015-20/V.S./QB/2144 dated
13.08.2019 received from Dy. Secretary (QB), Delhi Vidhan Sabha, Delhi
Secretariat, Delhi on the above quoted subject.

In this connection I am enclosing herewith the reply of the
aforementioned Vidhan Sabha Question in so far as the Delhi Jal Board is
concerned.

This issues with due approval of the competent authority.
Encl: As above.



(Paras Ram)

Director (Admn.& Personnel)

Tel. No. 23544794(O)

Email-id :- djbdirector@gmail.com

पारस राम / PARAS RAM

निदेशक (प्रशा. एवं कार्मिक)

Director (A&P)

दिल्ली जल बोर्ड, दिल्ली सरकार

D.J.B., Govt. of NCT of Delhi

विभाग का नाम :- दिल्ली जल बोर्ड

विभाग का पता :- निदेशक (प्रशासनिक एवं कार्मिक)

वरुणालय फेज - 2, करोल बाग, नई दिल्ली

अतारांकित प्रश्न संख्या :- 50

दिनांक :- 22.08.2019

प्रश्नकर्ता का नाम :- श्री राजेश गुप्ता, विधायक

क्या मुख्यमंत्री यह बताने की कृपा करेंगे कि :-

अ. क्र.	प्रश्न	उत्तर
(क)	वजीर पुर विधानसभा क्षेत्र में गंदे पानी और सीवर के पानी के जल भराव की अनुमानित कितनी मासिक शिकायतें प्राप्त होती हैं;	अनुमानित मासिक शिकायतें :- 1. गंदे पानी - 30 2. सीवर के पानी का जल भराव - 70
(ख)	भारत नगर पंपिंग पर कितने पंप हैं, कितने एमजीडी पंप करते हैं तथा उनकी क्षमता कितनी है;	भारत नगर पंपिंग पर पंप : 06 MGD - 02 nos. 05 MGD - 05 nos. हैं। 10 MGD पंपिंग करते हैं तथा पंप हाउस की क्षमता : 11 MGD
(ग)	क्या यह सत्य है कि इन पंपों को नया लगाया जा रहा है एवं लाइनों को भी ठीक किया जा रहा है; और	नहीं, नए पम्पसैट नहीं लगाए जा रहे हैं। एक नई राइजिंग मैन भारत नगर से डाली जा रही है।
घ)	किसी पंप के खराब हो जाने पर सीवर के पानी को निकालने की वैकल्पिक व्यवस्था क्या है?	प्राप्त मात्रा में स्टैंडबाई पंप उपलब्ध है।

निदेशक (प्रशासन एवं कार्मिक)

पारस राम / PARAS RAM
निदेशक (प्रशा. एवं कार्मिक)
Director (A&P)
दिल्ली जल बोर्ड, दिल्ली सरकार
D.J.B., Govt. of NCT of Delhi