

No. G-4(vi)/DJB/Dir.(A&P)/ Monsoon-2019/ Unst. 71/CM-27
DELHI JAL BOARD, GOVT. OF NCT OF DELHI
OFFICE OF THE DIRECTOR (ADMN. & PERSONNEL)
VARUNALAYA PHASE-II, KAROL BAGH, NEW DELHI – 110 005

Dated 21.08.2019

To

Shri Mahendra Gupta
Dy. Secretary, (Question Branch),
Delhi Vidhan Sabha Secretariat,
Old Secretariat, Delhi – 110054.

**Subject:- Vidhan Sabha Un-starred Question No. 71 due for
22.08.2019 asked by Ms. Bhawana Gaur, MLA.**


Sir,

Please refer to letter No. F-11(B-1)VI/2015-20/V.S./QB/2144 dated
13.08.2019 received from Dy. Secretary (QB), Delhi Vidhan Sabha, Delhi
Secretariat, Delhi on the above quoted subject.

In this connection I am enclosing herewith the reply of the
aforementioned Vidhan Sabha Question in so far as the Delhi Jal Board is
concerned.

This issues with due approval of the competent authority.

Encl: As above.


(Paras Ram)

Director (Admn.& Personnel)

Tel. No. 23544794(O)

Email-id :- djbdirector@gmail.com

पारस राम / PARAS RAM
निदेशक (प्रशा. एवं कार्मिक)
Director (A&P)
दिल्ली जल बोर्ड, दिल्ली सरकार
D.J.B., Govt. of NCT of Delhi

विभाग का नाम :- दिल्ली जल बोर्ड

विभाग का पता :- निदेशक (प्रशासनिक एवं कार्मिक)

वरुणालय फेज - 2, करोल बाग, नई दिल्ली

अतारांकित प्रश्न संख्या :- 71

दिनांक :- 22.08.2019

प्रश्नकर्ता का नाम :- सुश्री भावना गौड, विधायक

क्या मा. मुख्यमंत्री यह बताने की कृपा करेंगे कि :-

अ.क्र.	प्रश्न	उत्तर
(क)	पालम विधानसभा क्षेत्र में बने हुए कमांड टैंक की क्षमता कितने एम्.जी.डी. पानी के लिए है;	पालम विधानसभा क्षेत्र में बने हुए कमांड टैंक की क्षमता 13.22 एम्.जी.डी. पानी के लिए है।
(ख)	इस क्षेत्र में जनसंख्या व क्षेत्रफल के अनुसार कितने एम.जी.डी. पानी की आवश्यकता है;	इस क्षेत्र में जनसंख्या व क्षेत्रफल के अनुसार लगभग 13.14 एम.जी.डी. पानी की आवश्यकता है।
(ग)	इस क्षेत्र में इस कमांड टैंक से कितना पानी दिया जा रहा है;	इस क्षेत्र में इस कमांड टैंक से लगभग 7.00 एम.जी.डी पानी दिया जा रहा है।
घ)	क्या आने वाले समय में यह कमांड टैंक इस क्षेत्र की जनता को पर्याप्त पानी की आपूर्ति करने में सक्षम है; और	घ) एवं ङ) :- आने वाले समय में यह कमांड टैंक इस क्षेत्र की जनता को पर्याप्त पानी की आपूर्ति करने में सक्षम है।
ङ)	यदि नहीं, तो इसका भविष्य के लिए क्या विकल्प सोचा गया है?	

निदेशक (प्रशासन एवं कार्मिक)

पारस राम / PARAS RAM
निदेशक (प्रशा. एवं कार्मिक)
Director (A&P)
दिल्ली जल बोर्ड, दिल्ली सरकार
D.J.B., Govt. of NCT of Delhi