

**STOP CORONA : Wash your Hands, Wear Mask, Maintain Social Distancing**

	<p><b>DELHI JAL BOARD: GOVT. OF NCT OF DELHI</b> <b>OFFICE OF DIRECTOR (A &amp; P)</b> <b>VARUNALAYA PHASE-II</b> <b>KAROL BAGH, NEW DELHI-110005</b> <b>PHONE:- 011-23544794</b> <b>E-mail:- djbdirector@gmail.com</b></p>	 <p>स्वच्छ भारत एक कदम स्वच्छता की ओर</p>
---	---	--

No. G-4(vi)/DJB/Dir.(A&P)/2021/19

Dated : 28/07/2021

To

Shri Neeraj Aggarwal,  
Dy. Secretary, (Question Branch),  
Delhi Vidhan Sabha Secretariat,  
Old Secretariat, Delhi – 110054.

**Subject:- Vidhan Sabha Unstarred Question No. 122 due for 30.07.2021  
asked by Shri Om Prakash Sharma, MLA.**

Sir,

Please refer to your letter No. F-11(B-1)VI/2015-20/VSS/Ques.Branch/6046 dated 22.07.2021 on the above quoted subject.

In this connection I am enclosing herewith the reply of the aforementioned Vidhan Sabha Question in so far as the Delhi Jal Board is concerned.

This issues with the approval of the competent authority.

Encl: As above.

  
(Bansh Raj)  
Director (Admn.& Personnel)

निदेशक (प्रशासन एवं कार्मिक)  
Director (A&P)  
दिल्ली जल बोर्ड  
Delhi Jal Board

विभाग का नाम :- दिल्ली जल बोर्ड  
विभाग का पता :- निदेशक (प्रशासनिक एवं कार्मिक)  
करोल बाग, नई दिल्ली

अतारांकित प्रश्न संख्या :- 122  
दिनांक :- 30.07.2021  
प्रश्नकर्ता का नाम :- श्री ओम प्रकाश शर्मा, विधायक  
क्या माननीय जल मंत्री यह बताने की कृपा करेंगे कि:

अ. क्र.	प्रश्न	उत्तर
क)	विश्वास नगर विधान सभा क्षेत्र को किस-किस यूजीआर से और कितना कितना पानी आपूर्ति किया जाता है;	विश्वास नगर में निम्नलिखित जलाशयों द्वारा पानी की आपूर्ति की जाती है, जिसका विवरण इस प्रकार है:- 1. गाजीपुर - 1.00 MGD. 2. मंडावली PI - 3.50 MGD. 3. सूरजमल विहार - 1.96 MGD. 4. AGCR - 4.20 MGD. 5. लक्ष्मीनगर - 3.40 MGD.
ख)	क्या यह सत्य है कि यहाँ पानी की लाइन 15 फीट से 20 फीट तक जमीन के नीचे है, जिससे पानी की आपूर्ति करने में दिक्कत होती है; और	जी नहीं ।
ग)	पानी की भयंकर कमी को देखते हुए सरकार इस यूजीआर की क्षमता में कब तक और कितने की बढ़ोतरी करेगी और कब तक वर्षों पुरानी पानी की लाइन को बदलने की योजना है?	यू.जी.आर की क्षमता बढ़ने की अभी कोई योजना नहीं है। पानी की कमी को देखते हुए इन जलाशयों में पानी की मात्रा 0.2 MGD तीन ट्यूबवेल द्वारा बढ़ाई गई है और इस वित्तीय वर्ष में 06 अतिरिक्त ट्यूबवेल द्वारा पानी की मात्रा में 0.6 MGD वृद्धि करने की योजना है। पुरानी क्षतिग्रस्त पाईप लाइनों को आवश्यकता अनुसार व बजट उपलब्धतानुसार क्रमबद्ध तरीके से बदला जा रहा है।

  
निदेशक (प्रशासन एवं कार्मिक)

निदेशक (प्रशासन एवं कार्मिक)  
Director (A&P)  
दिल्ली जल बोर्ड  
Delhi Jal Board